



Cranmer Engineering, Inc.
Integrated Engineering Services

Sample Results

Lake Francis MWC
PO Box 422
Dobbins, CA 95935

Work Order: GIA0012

Received: 01/02/26 14:15

Reported: 01/12/26 13:35

Chemical-Quarterly Blended Arsenic

System Number: 5800805

Sample Site: Blended PSW#5800805_006_006
Sample Number GIA0012-01

Date Collected: 01/02/2026 11:35

Collected by: William Stotts

Title 22 Designation:

	Result	Units	Reporting Limit	Method	Analyst Initials	Analysis Setup Time	Analysis Date
Arsenic	4.24	µg/L	2.00	EPA 200.8	MDS	01/06/26 14:09	01/06/26

Term and Qualifier Definitions

Item	Definition
ND	None detected at or above the reporting limit

Justin Smith

Laboratory Manager

Integrating people, land and water.

1188 East Main Street, Grass Valley, CA 95945

Phone: (530) 273-7284 | Fax: (530) 273-9507 | www.cranmerengineeringinc.com | E.L.A.P. Certification No. 1936

Sampling • Analytical Testing • Courier Service • System Operators • Engineering • Surveying • Technical Reporting • Planning • Construction Mgmt.