

Lake Francis MWC  
PO Box 422  
Dobbins, CA 95935

**Work Order:** GHG0227

**Received:** 07/03/25 14:45

**Reported:** 07/22/25 10:45

Chemical-Quarterly Blended Arsenic

System Number: 5800805

**Sample Site:** Blended PSW#5800805-006  
**Sample Number** GHG0227-01

**Date Collected:** 07/03/2025 12:30  
**Collected by:** William Stotts  
Title 22 Designation:

	Result	Units	Reporting Limit	Method	Analyst Initials	Analysis Setup Time	Analysis Date
Arsenic	4.82	µg/L	2.00	EPA 200.8	MDS	07/18/25 13:34	07/18/25

### Term and Qualifier Definitions

Item	Definition
ND	None detected at or above the reporting limit



Justin Smith

Laboratory Manager

*Integrating people, land and water.*

1188 East Main Street, Grass Valley, CA 95945

Phone: (530) 273-7284 | Fax: (530) 273-9507 | [www.cranmerengineeringinc.com](http://www.cranmerengineeringinc.com) | E.L.A.P. Certification No. 1936

Sampling • Analytical Testing • Courier Service • System Operators • Engineering • Surveying • Technical Reporting • Planning • Construction Mgmt.