



**Cranmer Engineering, Inc.**  
Integrated Engineering Services

# Sample Results

Lake Francis MWC  
PO Box 422  
Dobbins, CA 95935

**Work Order:** GDF0133

**Received:** 06/02/21 13:46

**Reported:** 06/15/21 12:04

System Number: 5800805

Chemical-Well 05 Inorganic

**Sample Site:** Well 05 PSW#5800805-005

**Sample Number** GDF0133-01

**Date Collected:** 06/02/2021 10:20

**Collected by:** JW

Title 22 Designation:

	Result	Units	Reporting Limit	Method	Analyst Initials	Bacti Setup Time	Analysis Date
Aluminum	ND	µg/L	10.00	EPA 200.8	CDN		06/09/21
Antimony	ND	µg/L	1.200	EPA 200.8	CDN		06/09/21
Arsenic	12.28	µg/L	2.000	EPA 200.8	CDN		06/09/21
Barium	ND	µg/L	20.00	EPA 200.8	CDN		06/09/21
Beryllium	ND	µg/L	0.2000	EPA 200.8	CDN		06/09/21
Cadmium	ND	µg/L	0.2000	EPA 200.8	CDN		06/09/21
Chromium	ND	µg/L	2.000	EPA 200.8	CDN		06/09/21
Nickel	ND	µg/L	2.000	EPA 200.8	CDN		06/09/21
Selenium	ND	µg/L	1.000	EPA 200.8	CDN		06/09/21
Thallium	ND	µg/L	0.2000	EPA 200.8	CDN		06/09/21
Mercury	ND	µg/L	1.0	EPA 245.1	CDN		06/07/21
Fluoride	0.11	mg/L	0.10	EPA 300.0	CDN		06/02/21
Nitrate as N	ND	mg/L	0.10	EPA 300.0	CDN		06/02/21
Nitrite as N	ND	mg/L	0.10	EPA 300.0	CDN		06/02/21

### Term and Qualifier Definitions

Item	Definition
ND	None detected at or above the reporting limit

Justin Smith

Laboratory Manager

*Integrating people, land and water.*

1188 East Main Street, Grass Valley, CA 95945

Phone: (530) 273-7284 | Fax: (530) 273-9507 | www.cranmerengineeringinc.com | E.L.A.P. Certification No. 1936

Sampling • Analytical Testing • Courier Service • System Operators • Engineering • Surveying • Technical Reporting • Planning • Construction Mgmt.