



Cranmer Engineering, Inc.
Integrated Engineering Services

Sample Results

Lake Francis MWC
 PO Box 422
 Dobbins, CA 95935

Work Order: GFG0511

Received: 07/12/23 16:00

Reported: 07/27/23 17:56

System Number: 5800805

Chemical-Quarterly Blended Arsenic

Sample Site: Blended PSW#5800805-006

Sample Number: GFG0511-01

Date Collected: 07/12/2023 13:20

Collected by: William Stotts

Title 22 Designation:

	Result	Units	Reporting Limit	Method	Analyst Initials	Analysis Setup Time	Analysis Date
Arsenic	18.5	µg/L	2.00	EPA 200.8	NBB	07/21/23 12:34	07/21/23

Term and Qualifier Definitions

Item	Definition
ND	None detected at or above the reporting limit

Justin Smith

Laboratory Manager

Integrating people, land and water.

1188 East Main Street, Grass Valley, CA 95945

Phone: (530) 273-7284 | Fax: (530) 273-9507 | www.cranmerengineeringinc.com | E.L.A.P. Certification No. 1936

Sampling • Analytical Testing • Courier Service • System Operators • Engineering • Surveying • Technical Reporting • Planning • Construction Mgmt.