



**Cranmer Engineering, Inc.**  
*Integrated Engineering Services*

# Sample Results

Lake Francis MWC  
 PO Box 422  
 Dobbins, CA 95935

**Work Order:** GGJ0334

**Received:** 10/04/24 13:35

**Reported:** 10/17/24 15:09

System Number: 5800805

Chemical-Quarterly Blended Arsenic

**Sample Site:** Blended PSW#5800805-006  
**Sample Number** GGJ0334-01

**Date Collected:** 10/04/2024 11:10

**Collected by:** William Stotts

Title 22 Designation:

	Result	Units	Reporting Limit	Method	Analyst Initials	Analysis Setup Time	Analysis Date
Arsenic	7.39	µg/L	2.00	EPA 200.8	NBB	10/16/24 11:06	10/16/24

### Term and Qualifier Definitions

Item	Definition
ND	None detected at or above the reporting limit

Michelle Harlin For Justin Smith

Laboratory Manager

*Integrating people, land and water.*

1188 East Main Street, Grass Valley, CA 95945

Phone: (530) 273-7284 | Fax: (530) 273-9507 | [www.cranmerengineeringinc.com](http://www.cranmerengineeringinc.com) | E.L.A.P. Certification No. 1936

Sampling • Analytical Testing • Courier Service • System Operators • Engineering • Surveying • Technical Reporting • Planning • Construction Mgmt.