

Sample Site: 13882 Shirley Dr

Sample Number GHF0023-01

Sample Results

Lake Francis MWC PO Box 422 Dobbins, CA 95935 Work Order: GHF0023

Received: 06/02/25 13:15

Reported: 06/03/25 9:39

System Number: 5800805

Bacteria-Monthly Operator Services

Date Collected: 06/02/2025 11:10

Collected by: William Stotts

Title 22 Designation: Routine

		Reporting		Analyst	Analysis Setup	Analysis	
	Result	Units	Limit	Method	Initials	Time	Date
Total Coliform	<1.0	MPN/100 mL	1.0	SM 9223 B - Colilert 18	RN	06/02/25 14:22	06/03/25
E.coli	<1.0	MPN/100 mL	1.0	SM 9223 B - Colilert 18	RN	06/02/25 14:22	06/03/25
Chlorine Residual	ND	mg/L	0.05	Approved Methods	William	06/02/25 11:10	06/02/25

Term and Qualifier Definitions

Item	Definition

ND None detected at or above the reporting limit

Justin Smith

Laboratory Manager

Integrating people, land and water.



MONTHLY OPERATOR DRINKING WATER SYSTEM CHECKLIST

MONTH/YEAR: June /2025

ystem Name:	Lake Francis MWC	
perator: WE	3	
ate: 6-2-7	25	
ign In/Out Tin	mes:	

Yes	No	NA	Due Date if Not Complete	Item	Problems/ Comments
Visual	Inspecti	on			I Tradition Committee
	X			Any evidence of leaks, vandalism, weeds, security concerns?	
Wellhe	ad				
				Are the following OK?	
a) 🕅		a)□		a) Casing & seal condition	
b) 🔀		b)□		b) Casing vent in place & screened	
c)[c) 🗆	c)□		c) Cement slab	
Pump a	nd Com	ponents	and the second		
a) 📮	a)□	a)□		a) Is the pump at the well operating normally?:	
b) 🔀	b)□	b)□		b) Are the electrical control and junction boxes sealed?	
c)[A	c)□	c)□		c) Is the electrical conduit in good condition?	
d) 🖭	d)□	d)□ _		d) Is the sample tap in good condition?	*
Pressu	re Tank/	Bladder	Tank		
				Check that the following are OK:	
a)□	a)□	a) 🔯		a) No leaks, rusting, damage	
b)□	b)□	b)[<		b) Water logged or air logged	
c)□	c)□	c) 📮		c) Air release valve/ air volume control operating	
L	***************************************				

Page 3 of 4

MONTHLY OPERATOR DRINKING WATER SYSTEM CHECKLIST

System Name:	
Operator:	
Date:	
Sign In/Out Times:	

Yes	No	T	Due Date if		
-		NA	Not Complete	Item	Problems/ Comments
Storag	e lank	T			
				Check that the following are OK:	*
a) 🗇	a)□	a)□		a) No leaks, rusting, damage	
b)[[]	b)□	b)□		b) All valves open	W611 4-11172 400
c) 📮	c)□	c) 🗆		c) Tank support sound	Well 4-11123800 Well 5-9438000
	d)□	d)□		d) Access port secured	Well 5 - 9438000
e)[2	e)□	e)□		e) Vent screened	
				Water level <u>Foil</u> ft	
				Totalizer meter reading:	٠
Booste	r Pump		(4) **		
a)□	a)□	a) 🔯		a) Is the pump operating normally?:	
b)□	b)□	₫(d		b) Are the electrical control and junction boxes sealed?	
c)□	c) 🗆	c) 📮		c) Is the electrical conduit in good condition?	
d)□	d)□	d) 🔁		d) Is the sample tap in good condition?	
Distrib	ution Sy	stem	100 05 10 CT \$100 PLT		
				Check that the following are OK:	
. /.	a)□	a)□		a) All sample sites	
p)[[]	b)□	b)□		b) No leaks	
c)□	c)□	c)[P	9	c) Backflow prevention devices	

MONTH/YEAR: _____

Page 4 of 4

MONTHLY OPERATOR DRINKING WATER SYSTEM CHECKLIST

System Name:	
Operator:	
Date:	
Sign In/Out Times:	

Yes	No	NA	Due Date if	ltem	
L			Not Complete	Rein	Problems/ Comments
	e Injecti	a) 🗓		a) Any chlorine residual issues based on your review of the log? Raw chlorine specifications strokes Chlorine pump setting strokes Tank level on arrival gallons Chlorine residual in system ppm Ratio of water to chlorine gal water to gal CL2 Amount of raw chlorine added gallons	
b)□ c)□	b)□ c)□	a) [4] b) [5] c) [7]		Check that the following are OK: a) Chlorine system secure b) Condition of tubes, hoses and pipes (no leaks) c) Discharge hose condition d) Condition of storage tank	
Samplii	ig				
D				Dead ends and sampling locations flushed?	
6				Sampling conducted in accordance with sampling plans?	

MONTH/YEAR: _____